



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Operation Cost Minimization of Droop-Controlled AC Microgrids Using Multiagent-Based Distributed Control

Li, Chendan; Savaghebi, Mehdi; Guerrero, Josep M.; Coelho, Ernane A. A.; Quintero, Juan Carlos Vasquez

Published in:
Energies

DOI (link to publication from Publisher):
[10.3390/en9090717](https://doi.org/10.3390/en9090717)

Publication date:
2016

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):

Li, C., Savaghebi, M., Guerrero, J. M., Coelho, E. A. A., & Quintero, J. C. V. (2016). Operation Cost Minimization of Droop-Controlled AC Microgrids Using Multiagent-Based Distributed Control. *Energies*, 9(9), [717]. <https://doi.org/10.3390/en9090717>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Article

Operation Cost Minimization of Droop-Controlled AC Microgrids Using Multiagent-Based Distributed Control

Chendan Li ^{1,*}, Mehdi Savaghebi ¹, Josep M. Guerrero ¹, Ernane A. A. Coelho ² and Juan C. Vasquez ¹

¹ Department of Energy Technology, Aalborg University, Aalborg 9220, Denmark; mes@et.aau.dk (M.S.); joz@et.aau.dk (J.M.G.); juq@et.aau.dk (J.C.V.)

² Núcleo de Pesquisa em Eletrônica de Potência (NUPEP), Faculdade de Engenharia Elétrica (FEELT), Universidade Federal de Uberlândia (UFU), Uberlândia, Minas Gerais 38400-902, Brazil; ernane@ufu.br

* Correspondence: che@et.aau.dk; Tel.: +45-2382-3220

Academic Editor: Neville Watson

Received: 6 July 2016; Accepted: 29 August 2016; Published: 6 September 2016

Abstract: Recently, microgrids are attracting increasing research interest as promising technologies to integrate renewable energy resources into the distribution system. Although many works have been done on droop control applied to microgrids, they mainly focus on achieving proportional power sharing based on the power rating of the power converters. With various primary source for the distributed generator (DG), factors that are closely related to the operation cost, such as fuel cost of the generators and losses should be taken into account in order to improve the efficiency of the whole system. In this paper, a multiagent-based distributed method is proposed to minimize the operation cost in AC microgrids. In the microgrid, each DG is acting as an agent which regulates the power individually using a novel power regulation method based on frequency scheduling. An optimal power command is obtained through carefully designed consensus algorithm by using sparse communication links only among neighbouring agents. Experimental results for different cases verified that the proposed control strategy can effectively reduce the operation cost.

Keywords: AC microgrid; economic dispatch problem (EDP); operation cost minimization; droop control; frequency scheduling; incremental cost consensus; multiagent

1. Introduction

With the raising awareness of environmental problems and increasing demands for power supply reliability and quality, microgrids are becoming a promising solution to integrate renewable energy resources and to modernize the current electrical system at the distribution level. A microgrid can be described as a cluster of loads, distributed generation (DG) units and energy storage system (ESS) operated in a coordinated way to provide power supply to customers with higher reliability, and interacting with the utility grid at the point of common coupling (PCC) to import/export power and provide ancillary services [1–3]. To fully take advantage of microgrids' potential, numerous research works are dedicated to testing new microgrid control strategies [1–27].

In order to control and manage effectively a microgrid, hierarchical control is proposed to coordinate the resources according to different time scales [3]. In the lower level which is also named primary control and has the highest control bandwidth, a droop controller is often adopted to share the load demand among DGs. In the higher level, with relatively lower control bandwidth, advanced control purposes, such as frequency and voltage recovery, reactive power compensation, economic dispatch, unbalance and harmonics compensation, are identified for the energy management of microgrids.

Previously, the major concern for the control of microgrids was focused on sharing the active/reactive power among the DGs based on their respective kVA ratings, through a virtual impedance loop [4–7], adaptive tuning [8], and so on. With the increasing concern about the efficiency and cost of systems, higher level controllers for energy management are attracting more and more interest. Among the different tasks for the aforementioned energy management, the economic dispatch problem (EDP) is vital for the improvement of system efficiency while facilitating the commercialization of the microgrid. This is especially needed when there are various types of DGs coexisting in a microgrid.

The higher level control can be classified into two types according to how they realize the economic dispatch. One is based on centralized control [9–13], while the other is based on distributed control [14–27]. In order to dispatch the power optimally, in [9–12], the authors use a centralized controller to make the decisions for generating the optimal power generation commands based on the generation cost. In [13], the regulation of the power generation is realized by directly changing the droop coefficients according to the stability constrained optimization. Although centralized control enjoys the merits of accurate control and easy implementation, it encounters the following challenges: First, it requires heavy communication overheads due to the bidirectional communication links between every single unit in the system and the centralized controller. Second, due to the existence of a single centralized controller, which is needed to tackle the large amount of data from the sub-units and to make the decisions for the whole system, it places high demands on the computational capability of this unit, and renders the system susceptible to a single point of failure if this centralized controller fails. Moreover, as customers are becoming more aware of the cases where private information might be revealed in the patterns of how they consume the electricity, more customers (e.g., the owners of the resources in the microgrid) might not be willing to pass the consumption data on to the centralized controller.

In light of these concerns, decentralized control strategies are proposed as an alternative to overcome these shortcomings. Some of the decentralized methods directly use droop control to dispatch the power economically in a distributed way, due to the fact that it is simple to implement, requires no communication, and relies only on the local information. In [14], the operation cost information is incorporated in a weighted droop expression through calibrating the minimum and maximum operation cost in a linear way with respect to the droop gain. Although it works very well for most cases, it will lose its effectiveness when two DG units have the same maximum and minimum generation costs. Another work improves upon this idea by introducing a weighted droop expression which considers the nonlinear characteristic of the operation cost function [15]. However, despite the merit that there is no communication overhead, this method lacks adaptability to external changes of the cost without communication, which enables the higher level control to obtain cost information in a timely way.

Another possibility is using a multiagent approach, in which either a sub-function or a unit in the microgrid are taken as agents. Each agent has the properties of autonomy, reactivity, pro-activeness and social ability [16–27], and they exchange information with the corresponding agent to make the decisions locally for collaborative purposes. There are mainly two concepts that can be applied to form a multiagent platform. Some multiagent systems in microgrids are based on the market concept to maximize the benefits of generation units by analyzing the effects and evaluation of different auction algorithms [16–19]. This is also consistent with the market scenarios in a large power system. However, for a small scale network such as a microgrid, the computation load is too heavy. Moreover, although the auction process is decentralized, a special unit is still needed to collect the power requests from other users.

By combining the advantages of multiagent systems with simplicity, various consensus algorithms are proposed to manage the resources of a microgrid in economic fashion [24–27]. In [24], a consensus-based algorithm is proposed to coordinate the ESS units of a microgrid according to the efficiency. However, one leader agent is needed to broadcast the total active power deviation, thus compromising the decentralization feature. In [25], although a consensus algorithm is developed

to optimize the cost, it is only validated by using numerical simulations. In [26,27], an incremental cost consensus is proposed in the smart grid context, nevertheless the details of the power regulation realization are not given.

In this paper, a multiagent-based distributed operation cost minimization method is proposed to dispatch the power economically based on the generation cost of different DGs. Each DG is acting as an agent which regulates the power according to the command obtained through an incremental cost consensus algorithm by using sparse communication among the direct neighbours of each unit. First, the details of the proposed power regulation strategy based on frequency scheduling are introduced. The small signal model of the power regulation strategy by using frequency scheduling is developed, and the sensitivity of the control parameters in the controller is investigated. The proposed control strategy based on multiagent systems is then presented to set the optimal power commands. Experimental case studies of an AC microgrid with three different DG units are carried out to verify the proposed control methodology.

The main contribution of this work lies in two aspects. One is the formulation of the optimization problem for operational cost minimization based on a multiagent system using incremental cost consensus. For the other, this work has proposed a power regulation method based on frequency scheduling to track this optimal command. Overall, this work makes an initial effort to design and implement a distributed approach which combines the local power droop control of all the power electronics units and an incremental consensus algorithm on the optimization layer, and this method has reduced the operation cost of the whole system effectively.

The rest of the paper is organized as follows. In Section 2, the principle of the proposed frequency scheduling method for power regulation is introduced and analysed through small signal modelling. In Section 3, the detailed decentralized solution based on a multiagent system for minimizing the operation cost is provided, along with the formulation of the EDP, introduction and analysis of the incremental consensus, and the explanation of the system implementation. In Section 4, the experimental results are provided for different case studies to validate the proposed control strategy. Section 5 concludes the paper.

2. Frequency Scheduling for Power Regulation of Droop Controlled AC Microgrid

Droop control is widely used in microgrids to achieve autonomous power sharing without relying on communications. The conventional droop controller in an AC microgrid is expressed as:

$$\omega_i = \omega_{0i} - k_{\omega_i} P_i \quad (1)$$

$$E_i = E_{0i} - k_{E_i} Q_i \quad (2)$$

where ω_i is the output voltage frequency of the DG unit i , ω_{0i} is the nominal frequency, k_{ω_i} is the frequency droop gain, P_i is the output active power, E_i is the output voltage, E_{0i} is the nominal voltage amplitude, k_{E_i} is the voltage droop parameter and Q_i is the output reactive power. Note that from Equation (1), if k_{ω_i} and ω_{0i} are equal for all i units, the P_i will be equally shared. However, if we want to change the way how real power is shared among different DG units, there are two possibilities to realize it. As can be seen from Figure 1, either changing the frequency droop gain k_{ω_i} or changing the nominal frequency ω_{0i} will result in different power sharing.

In the previous work [5], adaptive frequency droop gain has been employed to reduce operation cost. Instead of adjusting the droop gain, the possibility of frequency scheduling is investigated in the paper. The control scheme block diagram of each DG is illustrated. As can be seen in Figure 2, outside the primary control which uses the traditional droop, the nominal frequency is modified according to the command of active power as is shown in the frequency scheduling block. Note here that one of the DGs sets the regulator as a proportional controller while all the others are using a proportional-integral controller in the block of frequency scheduling, since for an islanded microgrid it must have at least one DG unit to balance the supply-demand mismatch.




Figure 1. Two ways of real power regulation using frequency droop: (a) changing nominal frequency where frequency droop gain is fixed; and (b) changing frequency droop gain while keeping nominal frequency fixed.




Figure 2. Block diagram of frequency scheduling of each distributed generator (DG) unit.

The frequency scheduling controller can be expressed as:

$$\omega_{0i} = \omega^* + \delta\omega_p \quad (3)$$

The generic proportional integrator (PI) controller to regulate active power takes the form:

$$\delta\omega_p = k_p (P_{G,i} - P_i) - k_i \int (P_{G,i} - P_i) \quad (4)$$

Thus the frequency droop controller in Equation (1) can be expressed as:

$$\omega_i = \omega^* + \delta\omega_p - k_\omega P_i \quad (5)$$

where ω^* , $\delta\omega_p$, k_p , k_i and $P_{G,i}$ are the initial nominal frequency, modified term of nominal frequency, the proportional term of the power regulator, integral term of the power regulator and the command of generation power, respectively.

The mechanism of the proposed power regulation based on the frequency scheduling can also be illustrated by frequency droop scheme as in Figure 3. By adding the modified term to the nominal frequency, the resultant active power generated by unit i will become exactly the active power command. Note here the modified term can also be negative, and thus some units will reduce the active power generation.




Figure 3. Illustration of power regulation principle by frequency scheduling.

Assuming the output impedances of each converter are mainly inductive which may be enforced by adjusting properly the virtual impedance $Z_D(s)$, active power can be expressed as:

$$P_i = \frac{E_i V \sin \phi_i}{X_i} \quad (6)$$

where ϕ_i , V , E_i and X_i are the power angle, common bus voltage, and the magnitude of the output reactance for DG i , respectively.

Perturbing Equation (5) at the equilibrium point using Taylor series, the dynamics of power regulation of the system around the operation point in Laplace form can be expressed by the following equations omitting the higher order items [28]:

$$\Delta \omega_i(s) = \Delta \omega_p(s) - k_\omega \Delta P_i(s) \quad (7)$$

$$\Delta \phi_i = \frac{1}{s} \Delta \omega_i \quad (8)$$

Similarly, by perturbing Equation (6) at the equilibrium point and omitting the higher order Taylor series items, the small signal version of this equation can be expressed as:

$$\Delta p_i = G \Delta \phi_i(s) \quad (9)$$

where G is written as follows:

$$G = \frac{E_{ie} V_e \cos \phi_{ie}}{X_i} \quad (10)$$

where E_{ie} , V_e and ϕ_{ie} are the voltage of inverter i at the equilibrium point, which can be approximated as $E_{ie} \approx 1$ per unit, $V_e \approx 1$ per unit, $\phi_{ie} \approx 0$ per unit and $X_i = 0.001$ per unit.

Figure 4 shows the block diagram of the small signal model for power regulation using frequency scheduling. The model includes the droop control model, the plant model, and the power regulation model. The output of the low-pass-filter with the τ_p as the time constants, PI controller for power regulation, and the power angle are chosen as the state variables.




Figure 4. Block diagram of small signal model of the power regulation.

Thus, the small signal model of the power regulation dynamics can be written in state-space form as follows:

$$\dot{x}(t) = Ax(t) + Bu(t) \quad (11)$$

where B is unit vector and state variables $x(t)$ as shown in Figure 4, input vector $u(t)$ is $u(t) = \begin{bmatrix} \Delta\omega^* & \Delta P_{G,i}^* \end{bmatrix}$ and system matrix A is:

$$A = \begin{bmatrix} -\frac{1}{\tau_p} & \frac{G}{\tau_p} & 0 \\ -k_\omega & 0 & 1 \\ \frac{k_p - k_i \tau_p}{\tau_p} & -\frac{k_p G}{\tau_p} & 0 \end{bmatrix} \quad (12)$$

From Equation (12), the eigenvalues of matrix A are used to analyze the impact of the control parameters over the power control performance on the system stability. Figure 5a–c shows the trajectory of the modes in function of control parameters.

Figure 5b shows that as the integral term of the PI controller increases, the eigenvalues of the system move toward an unstable region. However, as is shown in Figure 5a, the proportional term has no significant effect on the stability. As can be seen from Figure 5c, the time constant of the low-pass filter for power calculation cannot be chosen arbitrarily, the large cut-off frequency will lead the system to instability.




Figure 5. Root-locus under different control parameters: (a) trace of modes as a function of proportional term of excitation system regulator: $0.0000001 < k_p < 0.008$; (b) trace of modes as a function of proportional term of excitation system regulator: $0.0001 < k_i < 0.02$ and (c) trace of modes as a function of proportional term of excitation system regulator: $0.05 < \tau_p < 0.5$.

3. Multiagent System for Operation Cost for Operation Cost Minimization Using Incremental Cost Consensus

In this section, the proposed distributed implementation of economic dispatch for operation cost minimization is introduced. Firstly, the problem of operation cost minimization is formulated. Then the proposed incremental cost consensus algorithm is explained, with its convergence analysis and convergence dynamic analysis. Finally, the implementation of the whole multiagent system is given.

3.1. Cost Function of a Distributed Generator Unit

For renewable energy generators (e.g., wind turbines and photovoltaic systems), we can assume the operation cost is zero. Moreover, normally these generators are working under maximum power point tracking (MPPT) mode to maximize the utilization of the renewable energy, hence they cannot be taken as the controllable generation to effectively participate. On the contrary, their variable generation along with unpredictable load requires consistent optimization for EDP. Here in this work, the backup

generator, e.g., fuel cell, diesel generator, and batteries are taken as the unit for EDP. Generally, the cost function of the fuel generator can be written as a quadratic cost function [8,9,29]. For the ESS, considering the power loss during charging and discharging operations, the cost function has a similar pattern to those for fuel generators [24]. The detailed derivation of the cost function can be found in [30]. In general, the cost function of the generator dispatched in EDP can be written as:

$$C_i(P_{G,i}) = \alpha_i P_{G,i}^2 + \beta_i P_{G,i} + \gamma_i \quad (13)$$

where α_i , β_i and γ_i are the coefficients related to the cost function for generation i .

Figure 6 illustrates the operation cost function for three different units (DG1, DG2, and DG3). The coefficients data can be found in Table 1.




Figure 6. Curve of cost function for three DG units.

Table 1. Coefficients of the Operation Cost Function.

Unit	α_i	β_i	γ_i
1	7.15×10^{-5}	7.5×10^{-3}	0.0002
2	4.75×10^{-5}	7.5×10^{-3}	0.0005
3	3.75×10^{-5}	7.3×10^{-3}	0.0001

3.2. Problem Statement

The purpose of the EDP is to minimize the operation cost of all the dispatchable generators. Thus the total cost of operation of a microgrid with n dispatchable generators is the summary of the cost of all of them, which can be expressed as:

$$C_{\text{total}} = \sum_{i=1}^n C_i(P_{G,i}) = \sum_{i=1}^n \alpha_i P_{G,i}^2 + \beta_i P_{G,i} + \gamma_i \quad (14)$$

where C_{total} is the total cost of the whole system.

Considering the constraints of power balance and power generation limitation, the objective function of this EDP considered here can be written as follows:

$$\begin{aligned} & \text{Min} \sum_{i=1}^n \alpha_i P_{G,i}^2 + \beta_i P_{G,i} + \gamma_i \\ & \text{s.t.} \\ & \sum_{i=1}^n P_{G,i} = P_D \\ & P_{G,i}^{\min} \leq P_{G,i} \leq P_{G,i}^{\max} \end{aligned} \quad (15)$$

where P_D denotes the total power demand of the system, $P_{G,i}^{\min}$ and $P_{G,i}^{\max}$ denote the minimum and maximum of the active power able to be generated by unit i , respectively.

3.3. Incremental Cost

The aforementioned constrained optimization problem can be solved using the Lagrange multiplier method [29]. Accordingly, incremental cost is introduced as a term to solve this EDP, which is defined as:

$$r_i = \frac{\partial C_i(P_{G,i})}{\partial P_{G,i}} = 2\alpha_i P_{G,i} + \beta_i \quad (16)$$

where r_i is the incremental cost of DG unit i .

If the power capacity limitation of the generator is not violated, the necessary condition for the existence of a minimum cost operation condition for the system is that the incremental cost rates of the all the generation units reach to the common value r^* .

This common value is also insightful even under the scenario when the generation capacity bound is reached. In this case, the optimal dispatch can be expressed as follows:

$$\begin{cases} \frac{\partial C_i(P_{G,i})}{\partial P_{G,i}} = r^* \text{ for } P_{G,i}^{\min} \leq P_{G,i} \leq P_{G,i}^{\max} \\ \frac{\partial C_i(P_{G,i})}{\partial P_{G,i}} \leq r^* \text{ for } P_{G,i} = P_{G,i}^{\max} \\ \frac{\partial C_i(P_{G,i})}{\partial P_{G,i}} \geq r^* \text{ for } P_{G,i} = P_{G,i}^{\min} \end{cases} \quad (17)$$

The analytical solution of r^* can be expressed combining Equations (15) and (16), as follows:

$$r^* = \frac{\sum_{i=1}^n \frac{\beta_i}{2\alpha_i} + P_D}{\sum_{i=1}^n \frac{1}{2\alpha_i}} \quad (18)$$

Conventionally, there is a microgrid centralized controller (MGCC), after collecting the load information on-line or through prediction algorithm, by the virtue of the incremental cost concept, optimal power dispatch command is generated and sent to all the generators of the system. This process needs bidirectional communication between the MGCC and all the generation units.

3.4. Incremental Cost Consensus Algorithm

In order to avoid the MGCC dependence, alternatively we introduce the multiagent system so as to shift the paradigm from a centralized to a distributed control system, and thus avoid the single point failure of the MGCC. In the distributed multiagent system, each local controller located in every DG unit can be taken as an agent, which communicates with their neighbours in the sparse communication network. Each agent adopts the same consensus algorithm to discover the global variables, conducts the optimization, makes the decision and controls the local generation directly.

The different communication topologies between the conventional centralized method and the consensus-based multiagent system are illustrated in Figure 7. In this example, it assumes that there are four DG units in the microgrid. Figure 7b only shows one possibility of the communication topology of the multiagent system, in which no centralized controller is needed and each local agent communicates with their neighbouring agents in a connected graph.

Here, a graph G will be used to model the communication network of the multiagent system. Let $G = (V, E)$ be a undirected graph with a set of vertices $V = \{1, 2, \dots, n\}$ and a set of edges $E \subseteq V \times V$. The undirected edge connects i and j is denoted by an unordered and distinct pair $(i, j) \in E$. The neighbours of vertices i is denoted as by $N_i = \{j \in V \mid (i, j) \in E\}$. An undirected graph is called connected if and only if there exists a path between any distinct pair of two vertices.




Figure 7. Communication topologies for two different control methodologies: (a) communication topology for centralized control; and (b) communication topology for multiagent based distributed control.

In the communication network of multiagent system, each agent can be represented by a vertex, and the edge between any pair of two different agents means the bidirectional communication link between this pair of agents. The basis updating process of agent i can be written as:

$$x_i[t+1] = \sum_{j=1}^n d_{ij} x_j[t] \quad (19)$$

where $x_j[t]$ is the consensus variable discovered by agent j at iteration t , $x_i[t+1]$ is the consensus variable discovered by agent j at iteration $t+1$, and d_{ij} is the coefficient associated with edge ij . The coefficients need to be designed in the algorithm to make consensus converge.

There are several methods to determine the coefficients d_{ij} [24,31–33], e.g., the Perron matrix [31], the uniform method [32], or the metropolis method [24,33], where D is the coefficients matrix of the communication system, and to guarantee the convergence of the system, D should satisfy the following two constraints:

- (1) D is the double-stochastic matrix, i.e., the sum of D 's row and columns are both ones;
- (2) The eigenvalues of D should be within a close disk $|\lambda_i| \leq 1$.

Here the same method used by [24] is chosen in this paper to be adaptive to changes of communication topology and guarantee good convergence speed. The coefficients are defined as:

$$d_{ij} = \begin{cases} 2/(n_i + n_j + 1) & j \in N_i \\ 1 - \sum_{j \in N_i} 2/(n_i + n_j + 1) & i = j \\ 0 & \text{otherwise} \end{cases} \quad (20)$$

where n_i is the number of neighbours of vertices i .

The updating rule of the proposed incremental consensus algorithm is designed as follows:

$$r_i[t+1] = \sum_{i \in N_i} d_{ij} r_j[t] + \varepsilon P_{D,i}[t] \quad (21)$$

$$P_{G,i}[t+1] = \frac{r_i[t+1] - \beta_i}{2\alpha_i} \quad (22)$$

$$P'_{D,i}[t+1] = P_{D,i}[t] - (P_{G,i}[t+1] - P_{G,i}[t]) \quad (23)$$

$$P_{D,i}[t+1] = \sum_{i \in N_i} d_{ij} P'_{D,j}[t] \quad (24)$$

where $r_i[t]$ is the incremental cost of agent i at the iteration t , ε is the feedback coefficients which controls the convergence of the consensus, and $P_{D,i}[t]$ is the estimation of the global supply-demand mismatch.

The initialization of the system can be set as follows:

$$\begin{cases} P_{G,i}[0] = 0 \\ P_{D,i}[0] = P_{L,i} \\ r_i[0] = \beta_i \end{cases} \quad (25)$$

3.5. Convergence Analysis of the Incremental Cost Consensus

In order to analyse the convergence of the designed consensus algorithm, the updating rule of each agent in Equations (21)–(24) can be rewritten in the following matrix form:

$$\mathbf{R}[t+1] = \mathbf{D}\mathbf{R}[t] + \varepsilon\mathbf{P}_D[t] \quad (26)$$

$$\mathbf{P}_G[t+1] = \mathbf{H}\mathbf{R}[t+1] - \mathbf{Q} \quad (27)$$

$$\mathbf{P}_D[t+1] = \mathbf{D}\mathbf{P}_D[t] - \mathbf{D}(\mathbf{P}_G[t+1] - \mathbf{P}_G[t]) \quad (28)$$

where \mathbf{R} , \mathbf{P}_D , and \mathbf{P}_G are the column vectors of r_i , $P_{D,i}$ and $P_{G,i}$; and \mathbf{Q} is the column of $\frac{\beta_i}{2\alpha_i}$, and $\mathbf{H} = \text{diag}([1/2\alpha_1, 1/2\alpha_2, \dots, 1/2\alpha_n])$.

The updating rule can be further reduced to:

$$\begin{bmatrix} \mathbf{R}[t+1] \\ \mathbf{P}_D[t+1] \end{bmatrix}_{2n \times 1} = \mathbf{M} \begin{bmatrix} \mathbf{R}[t] \\ \mathbf{P}_D[t] \end{bmatrix}_{2n \times 1} \quad (29)$$

$$\mathbf{M} = \begin{bmatrix} \mathbf{D} & \varepsilon\mathbf{I}_n \\ -\mathbf{D}\mathbf{H}(\mathbf{D}-\mathbf{I}_n) & \mathbf{D}(\mathbf{I}_n - \varepsilon\mathbf{H}) \end{bmatrix}_{2n \times 2n} \quad (30)$$

where \mathbf{I}_n is a $n \times n$ identity matrix, since ε is very small, it can be neglected, so that we can make the following approximation:

$$|\lambda\mathbf{I}_{2n} - \mathbf{M}| = |(\lambda\mathbf{I}_n - \mathbf{D})^2 - \varepsilon\mathbf{I}_n\mathbf{D}\mathbf{H}(\mathbf{D}-\mathbf{I}_n)| \approx |\lambda\mathbf{I}_n - \mathbf{D}|^2 \quad (31)$$

Therefore, the eigenvalues of \mathbf{M} are the same as those of \mathbf{D} . As \mathbf{D} is designed as Equation (9), it can be verified that \mathbf{M} has $[\mathbf{1}_n, \mathbf{0}_n]^T$ when $\lambda_1 = 1$, that is:

$$\begin{bmatrix} \mathbf{D} & \varepsilon\mathbf{I}_n \\ -\mathbf{D}\mathbf{H}(\mathbf{D}-\mathbf{I}_n) & \mathbf{D}(\mathbf{I}_n - \varepsilon\mathbf{H}) \end{bmatrix}_{2n \times 2n} \begin{bmatrix} \mathbf{1}_n \\ \mathbf{0}_n \end{bmatrix} = \begin{bmatrix} \mathbf{D} \\ -\mathbf{D}\mathbf{H}(\mathbf{D}-\mathbf{I}_n)\mathbf{1}_n \end{bmatrix} = \begin{bmatrix} \mathbf{1}_n \\ \mathbf{0}_n \end{bmatrix} \quad (32)$$

As it is proved in [12], this property of \mathbf{M} means that the system of Equation (18) will converge to span $[\mathbf{1}_n, \mathbf{0}_n]^T$ with infinite number of iterations, that is:

$$\begin{bmatrix} R[\infty] \\ P_D[\infty] \end{bmatrix}_{2n \times 1} = r^* \begin{bmatrix} \mathbf{1}_n \\ \mathbf{0}_n \end{bmatrix} \quad (33)$$

Premultiplying $\mathbf{1}_n^T$ to both sides of Equation (28), it yields:

$$\mathbf{1}_n^T \cdot \mathbf{P}_D[t+1] = \mathbf{1}_n^T \cdot \mathbf{D}\mathbf{P}_D[t] - \mathbf{1}_n^T \cdot \mathbf{D}(\mathbf{P}_G[t+1] - \mathbf{P}_G[t]) = \mathbf{1}_n^T \cdot \mathbf{P}_D[t] - \mathbf{1}_n^T \cdot (\mathbf{P}_G[t+1] - \mathbf{P}_G[t]) \quad (34)$$

$$\mathbf{1}_n^T \cdot \mathbf{P}_D[t+1] + \mathbf{1}_n^T \cdot \mathbf{P}_G[t+1] = \mathbf{1}_n^T \cdot \mathbf{P}_D[t] + \mathbf{1}_n^T \cdot \mathbf{P}_G[t] \quad (35)$$

Since $P_D[\infty] = 0$, then:

$$\mathbf{1}_n^T \cdot \mathbf{P}_G[\infty] = \mathbf{1}_n^T \cdot \mathbf{P}_D[0] - \mathbf{1}_n^T \cdot \mathbf{P}_G[0] = P_D \quad (36)$$

Considering Equation (11), there is:

$$\mathbf{1}_n^T \cdot \mathbf{P}_G[\infty] = \mathbf{1}_n^T \cdot \mathbf{H}\mathbf{R}[\infty] - \mathbf{1}_n^T \cdot \mathbf{Q} = \mathbf{1}_n^T \cdot \mathbf{H} \cdot \mathbf{1}_n^T \cdot \mathbf{r}^* - \mathbf{1}_n^T \cdot \mathbf{Q} \quad (37)$$

The incremental cost will finally converge to Equation (18).

3.6. Convergence Dynamics

In order to pre-test the proposed consensus algorithm and to investigate the impact of control parameters and topology on the convergence, a simulation study is conducted with three units under different scenarios. The cost function coefficients of the three units are listed in Table 1. The sampling time of the communication layer is 0.01 s. The impact of the feedback coefficients is firstly investigated. As can be seen from Figure 8a–c, as this parameter gets larger, the speed of convergence increases. However, with too large a parameter value, there will be an overshoot in the convergence process. Moreover, the robustness to the communication topology change is tested. At the beginning, these three units communicate with their neighbours in a circle. After 1 s, the link between unit 1 and unit 3 is lost. Then, after 2 s, the link between unit 2 and unit 3 is also lost, and unit 3 is disconnected from the system. As can be seen in Figure 8d, the loss of one communication link doesn't stop the system from converging to the common incremental cost, but only the speed of the convergence is compromised since the communication topology is still a connected graph. After the unit 3 is disconnected from the system, under the new communication topology, unit 1 and unit 2 converge to a new value, which shows the effectiveness of the algorithm under the topology changes.




Figure 8. Consensus dynamics with different ϵ and topologies: (a) convergence curve with $\epsilon = 0.0001$; (b) convergence curve with $\epsilon = 0.0005$; (c) convergence curve with $\epsilon = 0.0009$; and (d) convergence curve with changing topologies.

3.7. Multiagent System Implementation

An example of microgrids is shown in Figure 9. The microgrid is composed of different kinds of generators and various load. Since normally we configure the renewable in MPPT mode as current source converter and thus only other backup generators which are dispatchable are considered for optimization. Each dispatchable generator is controlled by an agent, and all the agents can exchange the information through a sparse communication network with a connected graph topology.




Figure 9. Example microgrid with multiagent system.

The implementation of the multiagent system is a distributed control in which each agent has an identical local control. The local control in a hierarchical structure from bottom to top consists of primary control, frequency regulation for power control, and consensus algorithm for optimal dispatch. The structure is shown in Figure 10.




Figure 10. Control scheme of proposed control strategy for each agent.

In the primary level, droop control is adopted to share the power autonomously. To regulate the real power, the nominal frequency is changed according to the mismatch of the actual power generation and the optimal power command. The optimal power command is obtained through the distributed incremental consensus algorithm.

4. Experimental Results

In order to verify the proposed algorithm, a number of case studies are carried out for an example of a microgrid with three different DG units having different generation cost. As is shown in Figure 11, the experimental setup is consisted of three Danfoss 2.2 kW inverters (Danfoss, Denmark) ended with LC filters, a dSPACE1006 real-time control and acquisition platform and its control desk software (dSPACE GmbH, Paderborn, Germany) and two resistive loads. The details of the experiment configuration are shown in Figure 12. The coefficients of the operation cost function of each unit are listed in Table 1, and the parameters of the system are listed in Table 2.




Figure 11. Experimental setup.




Figure 12. Experimental configuration.

Table 2. Parameters of the system.

	Parameters	Symbol	Value	Units
Electrical parameters	DC link voltage	V_{dc}	650	V
	Nominal microgrid voltage	E_{0i}	220	V
	Nominal frequency	ω_0^*	314	rad/s
	Power Rating of each DG unit	P_{max}	2.2	kW
	Switching frequency	f_s	10k	Hz
	LC filter inductor for each DG unit	L_f	1.8	mH
	LC filter capacitor for each DG unit	C_f	27	μF
	Resistive load 1	R_{d1}	76.67	Ω
	Resistive load 2	R_{d2}	76.67	Ω
Control parameters	Line impedance	L_{line}	1.8	mH
	Cut-off frequency of LPF for each DG unit	ω_f	0.7	rad/s
	Frequency droop gain for each DG unit	$k_{\omega i}$	0.002	rad/Ws
	Amplitude droop gain for each DG unit	k_{Ei}	0.02	V/Var
	Virtual resistance	R_v	0.1	Ω
	Proportional term of the power regulation	k_p	0.000001	-
	Integral term of power regulation	k_i	0.01	s^{-1}
	Convergence coefficient	ε	0.0005	-

4.1. Case Study 1: Compare with Conventional Droop

In the first case study, the power dispatch resulting from the using the proposed approach is compared with that using the conventional droop control. At the beginning, the conventional droop is adopted, and a 76.77 Ω load is connected. As is can be seen in Figure 13b, the load is evenly shared among three units. Then, the operation cost minimization is activated and power is dispatched accordingly. The operation cost is significantly reduced up to 40.93% with the optimization as is shown in Figure 13a. The system frequency is shown in Figure 13c. The frequency is changed in order to trace the power command given by the consensus algorithm.




Figure 13. Experimental results of comparison between conventional droop and optimization. (a) operation cost; (b) real power; and (c) frequency given.

4.2. Case Study 2: Load Change

In this case study, the load step response is tested using the proposed algorithm. In the beginning, a resistive load with $76.67\ \Omega$ is connected, and later, another $76.67\ \Omega$ is connected in parallel. The resulting power dispatch is shown in Figure 14b. Under these two conditions, the costs are reduced up to 40.75% and 37.98% compared with that using only traditional droop, respectively. Then, the operation cost minimization is activated and power is dispatched accordingly. The operation cost is significantly reduced with the optimization process as is shown in Figure 14a. The system frequency is shown in Figure 14c. As can be seen, when the total load of the system increases, the system frequency will reduce. During the entire process, the frequency is frequently modified to trace the power command.




Figure 14. Experimental results of transient response of load changing with proposed algorithm. (a) operation cost; (b) real power; and (c) frequency given.

4.3. Case Study 3: Disconnecting One Distributed Generation Unit

In this case study, the proposed algorithm is tested under the condition where one DG unit is disconnected and connected again. As is can be seen in Figure 15b, the power is firstly dispatched optimally among three units, and then when the third unit is disconnected, the power is shared among the remaining two units. Under both cases, the costs are reduced using optimization compared with using conventional droop.

The system frequency is shown in Figure 15c. This experiment shows the robustness of the proposed consensus algorithm under the loss of one DG unit. This experiment illustrates very well that the proposed method is superior compared with the traditional approach in that in this scenario the approach with a centralized controller cannot cope with.




Figure 15. Experimental results of transient response with one DG unit disconnected with proposed algorithm. (a) operation cost; (b) real power; and (c) frequency given.

5. Conclusions

In this work, a multiagent-based distributed operation cost minimization method is proposed to dispatch the power economically based on the different generation cost of DG units. Each DG unit is acting as an agent which regulates the power according to the command obtained by the consensus algorithm with only using communication with direct neighbours. A detailed power regulation method based on frequency scheduling is proposed, analysed and implemented. An incremental cost consensus algorithm is designed to obtain the power dispatch command for each DG unit. The proposed algorithm is verified in a testbed microgrid with three different DG units. With this strategy, the operation cost is reduced effectively. Further, the system is robust against communication failures and unplanned loss of a generation unit.

Author Contributions: Chendan Li conceived and designed the experiments; Chendan Li performed the experiments; Chendan Li analyzed the data; Josep M. Guerrero, Ernane A. A. Coelho and Juan C. Vasquez contributed reagents/materials/analysis tools; Chendan Li and Mehdi Savaghebi wrote the paper.

Conflicts of Interest: The founding sponsors had no role in the design of the study; in the collection, analyses, or interpretation of data; in the writing of the manuscript, and in the decision to publish the results.

References

1. Katiraei, F.; Iravani, R.; Hatziargyriou, N.; Dimeas, A. Microgrid Management. *IEEE Power Energy Mag.* **2008**, *6*, 54–65. [[CrossRef](#)]
2. Olivares, D.E.; Mehrizi-Sani, A.; Etemadi, A.H.; Cañizares, C.A.; Iravani, R.; Kazerani, M.; Hajimiragha, A.H.; Gomis-Bellmunt, O.; Saeedifard, M.; Palma-Behnke, R.; et al. Trends in microgrid control. *IEEE Trans. Smart Grid* **2014**, *5*, 1905–1919. [[CrossRef](#)]

3. Guerrero, J.M.; Vasquez, J.C.; Matas, J.; de Vicuña, L.G.; Castilla, M. Hierarchical control of droop-controlled AC and DC microgrids—A general approach toward standardization. *IEEE Trans. Ind. Electron.* **2011**, *58*, 158–172. [[CrossRef](#)]
4. Guerrero, J.M.; Berbel, N.; Matas, J.; De Vicuña, L.G.; Miret, J. Decentralized control for parallel operation of distributed generation inverters in microgrids using resistive output impedance. In Proceedings of the 32nd Annual Conference on IEEE Industrial Electronics Conference (IECON 2006), Paris, France; 2006; pp. 5149–5154.
5. He, J.; Li, Y.W.; Guerrero, J.M.; Blaabjerg, F.; Vasquez, J.C. An islanding microgrid power sharing approach using enhanced virtual impedance control scheme. *IEEE Trans. Power Electron.* **2013**, *28*, 5272–5282. [[CrossRef](#)]
6. Li, Y.W.; Kao, C.N. An accurate power control strategy for power-electronics-interfaced distributed generation units operating in a low-voltage multibus microgrid. *IEEE Trans. Power Electron.* **2009**, *24*, 2977–2988.
7. Haddadi, A.; Joos, G. Load sharing of autonomous distribution-level microgrids. In Proceedings of the 2011 IEEE Power and Energy Society General Meeting, San Diego, CA, USA, 24–29 July 2011.
8. Mohamed, A.R.I.; El-Saadany, E.F. Adaptive decentralized droop controller to preserve power sharing stability of paralleled inverters in distributed generation microgrids. *IEEE Trans. Power Electron.* **2008**, *23*, 2806–2816. [[CrossRef](#)]
9. Mohamed, F.A.; Koivo, H.N. Online management of microgrid with battery storage using multiobjective optimization. In Proceedings of the International Conference on Power Engineering, Energy and Electrical Drives, Setubal, Portugal, 12–14 April 2007.
10. Augustine, N.; Suresh, S.; Moghe, P.; Sheikh, K. Economic dispatch for a microgrid considering renewable energy cost functions. In Proceedings of the 2012 IEEE PES Innovative Smart Grid Technologies (ISGT), Washington, DC, USA, 16–20 January 2012.
11. Chen, C.; Duan, S.; Cai, T.; Liu, B.; Hu, G. Smart energy management system for optimal microgrid economic operation. *LET Renew. Power Gener.* **2011**, *5*, 258–267. [[CrossRef](#)]
12. Jiang, Q.; Xue, M.; Geng, G. Energy management of microgrid in grid-connected and stand-alone modes. *IEEE Trans. Power Syst.* **2013**, *28*, 3380–3389. [[CrossRef](#)]
13. Barklund, E.; Pogaku, N.; Prodanovic, M.; Hernandez-Aramburo, C.; Green, T.C. Energy management in autonomous microgrid using stability-constrained droop control of inverters. *IEEE Trans. Power Electron.* **2008**, *23*, 2346–2352. [[CrossRef](#)]
14. Nutkani, U.; Loh, P.C.; Blaabjerg, F. Droop scheme with consideration of operating costs. *IEEE Trans. Power Electron.* **2014**, *29*, 1047–1052. [[CrossRef](#)]
15. Nutkani, U.; Loh, P.C.; Wang, P.; Blaabjerg, F. Cost-Prioritized Droop Schemes for Autonomous AC Microgrids. *IEEE Trans. Power Electron.* **2015**, *30*, 1109–1119. [[CrossRef](#)]
16. Dimeas, L.; Hatziargyriou, N.D. Operation of a multiagent system for microgrid control. *IEEE Trans. Power Syst.* **2005**, *20*, 1447–1455. [[CrossRef](#)]
17. Divenyi, D.; Dan, A.M. Agent-based modeling of distributed generation in power system control. *IEEE Trans. Sustain. Energy* **2013**, *4*, 886–893. [[CrossRef](#)]
18. Nunna, H.S.V.S.K.; Doolla, S. Multiagent-based distributed-energy-resource management for intelligent microgrids. *IEEE Trans. Ind. Electron.* **2013**, *60*, 1678–1687. [[CrossRef](#)]
19. Cintuglu, M.H.; Martin, H.; Mohammed, O.A. Real-Time Implementation of Multiagent-Based Game Theory Reverse Auction Model for Microgrid Market Operation. *IEEE Trans. Smart Grid* **2015**, *6*, 1064–1072. [[CrossRef](#)]
20. Manickavasagam, K. Intelligent Energy Control Center for Distributed Generators Using Multi-Agent System. *IEEE Trans. Power Syst.* **2014**, *30*, 2442–2449. [[CrossRef](#)]
21. Logenthiran, T.; Naayagi, R.T.; Woo, W.L.; Phan, V.T.; Abidi, K. Intelligent control system for microgrids using multiagent system. *IEEE J. Emerg. Sel. Top. Power Electron.* **2015**, *3*, 1036–1045. [[CrossRef](#)]
22. McArthur, S.D.J.; Davidson, E.M.; Catterson, V.M.; Dimeas, A.L.; Hatziargyriou, N.D.; Ponci, F.; Funabashi, T. Multi-agent systems for power engineering applications—Part II: Technologies, standards, and tools for building multi-agent systems. *IEEE Trans. Power Syst.* **2007**, *22*, 1753–1759. [[CrossRef](#)]

23. McArthur, S.D.J.; Davidson, E.M.; Catterson, V.M.; Dimeas, A.L.; Hatziargyriou, N.D.; Ponci, F.; Funabashi, T. Multi-agent systems for power engineering applications—Part I: Concepts, approaches, and technical challenges. *IEEE Trans. Power Syst.* **2007**, *22*, 1743–1752. [[CrossRef](#)]
24. Xu, Y.; Zhang, W.; Hug, G.; Kar, S.; Li, Z. Cooperative control of distributed energy storage systems in a microgrid. *IEEE Trans. Smart Grid* **2015**, *6*, 238–248. [[CrossRef](#)]
25. Yang, S.; Tan, S.; Xu, J.-X. Consensus based approach for economic dispatch problem in a smart grid. *IEEE Trans. Power Syst.* **2013**, *28*, 4416–4426. [[CrossRef](#)]
26. Xu, Y.; Li, Z. Distributed optimal resource management based on consensus algorithm in a microgrid. *IEEE Trans. Ind. Electron.* **2015**, *62*, 2584–2592. [[CrossRef](#)]
27. Zhang, Z.; Chow, M.Y. Convergence analysis of the incremental cost consensus algorithm under different communication network topologies in a smart grid. *IEEE Trans. Power Syst.* **2012**, *27*, 1761–1768. [[CrossRef](#)]
28. Tuladhar, A.; Jin, K.; Unger, T.; Mauch, K. Control of parallel inverters in distributed AC power systems with consideration of line impedance effect. *IEEE Trans. Ind. Appl.* **2000**, *36*, 131–138. [[CrossRef](#)]
29. Wood, J.; Wollenberg, B.F. *Power Generation, Operation, and Control*; Wiley: New York, NY, USA, 1996.
30. Li, C.; de Bosio, F.; Chaudhary, S.K.; Graells, M.; Vasquez, J.C.; Guerrero, J.M. Operation cost minimization of droop-controlled DC microgrids based on real-time pricing and optimal power flow. In Proceedings of the 41st Annual Conference of the IEEE Industrial Electronics Society (IECON 2015), Yokohama, Japan, 9–12 September 2015.
31. Olfati-Saber, R.; Fax, A.; Murray, R.M. Consensus and cooperation in networked multi-agent systems. *Proc. IEEE* **2007**, *95*, 215–233. [[CrossRef](#)]
32. Lin, X.; Boyd, S. Fast linear iterations for distributed averaging. *Syst. Control Lett.* **2004**, *53*, 65–78.
33. Lin, X.; Boyd, S.; Kim, S.J. Distributed average consensus with least-mean-square deviation. *J. Parallel Distrib. Comput.* **2007**, *67*, 33–46.



© 2016 by the authors; licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC-BY) license (<http://creativecommons.org/licenses/by/4.0/>).